



SEABROOK FIRE DEPARTMENT

87 Centennial Street

Seabrook, NH 03874

Phone: 603-474-2611 Fax: 603-474-5187

seabrooknh.info

William J Edwards
Fire Chief
603-474-3880

Lawrence "Koko" Perkins
Deputy Fire Chief
603-474-5300

THE FOLLOWING INFORMATION MUST BE PROVIDED WITH APPLICATION BEFORE A FIRE ALARM PERMIT CAN BE ISSUED:

Two (2) sets of complete plans.

"Complete" indicates that all of the following are present:

1. Letter from designer reflecting that plans meet all requirements of NH State Fire Code SAF-C-6000 as adopted, including NFPA 1, NFPA 70, and NFPA 72, as well as all local ordinances of the Town of Seabrook.	
2. All floor plans; to include location of devices.	
3. Specification sheets for all devices.	
4. Wiring/ Riser diagrams and battery calculations.	
5. Enunciator layout and compatibility of devices.	

IMPORTANT NOTE: Depending upon the scope of work, a review may be required by a Fire Protection Engineer (FPE) prior to acceptance by the Fire Department. Reviews by NH registered professional engineers with a specialty in Fire Protection **only** are acceptable. Any deviations from the approved plan must be submitted to the FPE of record for review; then stamped and submitted to the Fire Department prior to final testing.