

TOWN OF
Seabrook, New Hampshire

99 LAFAYETTE ROAD
PO BOX 456 - 03874-0456
PH. (603) 474-3311 - FAX (603) 474-8007
WWW.SEABROOKNH.INFO

B2025-WTR-12

Proposal Due Date:
August 28, 2025

ADDENDUM #2 –

Questions:

Responses are noted in red

1. What size is the manway? Minimum 12" required. **Tanks have been inspected by divers before. Standard size**
2. Where is the manway located on the tank? What is the approximate water temperature? **On top of the tank.**
3. What is the estimated flow rate? **We can adjust the flow rate for hours at a time.**
4. What is the estimated water clarity? **Clear**
5. Is the sediment build up on the bottom of the tank? **We expect very little.**
6. Do you have a drawing of the tank? **No**
7. When would you like to accomplish this? **Finish by this time next year**
8. Do you have historical Data, previous reports? **No, First inspection since painting.**
9. You mention inspection of the walls, Is this just visual? UTT? Weld inspection? **Visual**
10. Do you have a code and acceptance criteria for the condition and integrity of the tank? **Industry standard**
11. Do you have procedures, codes, acceptance for the coating criteria? **Industry standard**

The Request for Proposals is modified as set forth in this Addendum. The original RFP Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the RFP. Respondent shall take this Addendum into consideration when preparing and submitting its Proposal.

This Addendum must be Signed & Returned with your Proposal.

Authorized Signature of Proposer

Company Name

APPROVED



William M. Manzi III
Town Manager

(Original Signature on Document in Procurement Files)

Date Issued: August 21, 2025