

Town of Seabrook
Seabrook, New Hampshire

	<u>Site</u>	<u>Location</u>	<u>Date</u>	<u>Hardness Results</u>	<u>Date</u>	<u>Iron Results</u>
Gravel Packed Wells	GPW 1	46 True Rd	04/11/13	135 mg CaCO ₃ /L	08/28/12	<0.01 mg/L
	GPW 2	46 True Rd	not required in 2012/2013	mg CaCO ₃ /L	08/28/12	0.143 mg/L
	GPW 3	54 Ledge Rd	04/11/13	219 mg CaCO ₃ /L	08/28/12	0.222 mg/L
	GPW 4	54 Ledge Rd	not required in 2012/2013	mg CaCO ₃ /L	08/28/12	0.201 mg/L
	GPW 7	54 Ledge Rd	04/11/13	164 mg CaCO ₃ /L	08/29/12	0.036 mg/L

	<u>Site</u>	<u>Location</u>	<u>Date</u>	<u>Hardness Results</u>	<u>Date</u>	<u>Iron Results</u>
WTP	514	550 Rte 107	not required in 2012/2013	mg CaCO ₃ /L	05/10/12	0.055 mg/L
	515	550 Rte 107	04/11/13	122 mg CaCO ₃ /L	03/28/11	0.013 mg/L

Avg. Grain 7.8

Hardness Scale (NHDES)

Soft Water = 0 - 75 mg/L as CaCO₃

Somewhat Hard Water = 76 - 150 mg/L as CaCO₃

Hard Water = 151 - 300 mg/L as CaCO₃

Very Hard Water = 301 and up mg/L as CaCO₃